

S
A
M
P
L
E

Disability	>>) – Facilities
------------	----------------------

Name of Premises:		Document Downloaded:	
Address:		Printer Name:	
Description:			

DAA Ref.	Issue	Technical Tips	and Observations	Action Required	Action Completed	Completion Date
13.1	Is seating provided at intervals on long routes or where waiting is likely	A rest point should be provided at least every 40M				
13.2	Are seats stable with arm rests offering firm support	Consider a range of heights from 420mm				
13.3	Can wheelchair users pull up in a waiting area	Consider creating a space wide				
13.4	Are telephones fixed at a height that can be easily used by a wheelchair person	Height should be 750				
13.5	Are audible alarms supplemented by visual alarms	This is particularly important for an emergency evacuation				
13.6	Are controls easy to distinguish	Think of tone, colour, and sound variations for key pads and similar facilities				
13.7						
13.8						
13.9						

Duty Holder Name:

Signature:

Date:

me:

S

A

M

P

L

E