

Disability Access

Lifts and Platform Lifts

| | |
|-------------------|--|
| Name of Premises: | |
| Address: | |
| Description: | |

| | |
|----------------------|--|
| Document Downloaded: | |
| Author Name: | |
| | |
| Editor: | |

| DAA Ref. | Issue | Technical Tips |
|----------|--|--|
| 9.1 | Passenger lift available for vertical circulation within the building of more than one storey | If not <ul style="list-style-type: none"> Consider additional refurbishment Can a lift platform be converted to a stair case |
| 9.2 | Are the dimensions sufficient to allow space for a wheel chair user | Door opening 800mm of lift 1400mm and a 800mm |
| 9.3 | Support rails in car correctly designed and positioned | Rails at 900mm height around the lift |
| 9.4 | Delayed action closer override | Not to confused with pressure system |
| 9.5 | Controls, including emergency call, located easily using visual or tactile information and within reach of all users | Controls between 900 1200mm |
| 9.6 | Voice indication of floor reached | Not required for a two building |
| 9.7 | Location of lift clearly marked | Should be well signed reception area |
| 9.8 | Sufficient space to manoeuvre outside the lift | Clear area free from 1500mm X 1500mm |
| 9.9 | Platform lifts safely approached at the top of stairs | Ensure that safe distance stair case |

| Findings and Observations | Action Required | Action Completed | Completion Date |
|---------------------------|-----------------|------------------|-----------------|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

| | | |
|------|--|---|
| 9.10 | Is the lift platform of an adequate size | Depth of 1400mm and 900mm |
| 9.11 | In the event of a power failure or emergency, does the platform automatically return to the lower level and allow egress | Essential in an emergency evacuation |
| 9.12 | Can the platform be folded away when not in use | Important if the width of the case when platform is wider than 1400mm |
| 9.13 | | |
| 9.14 | | |
| 9.15 | | |

| | |
|-------------------|--|
| Duty Holder Name: | |
| Signature: | |
| Date: | |

| | | | |
|--|--|--|--|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

| | |
|-----|--|
| me: | |
|-----|--|

S
A
M
P
L
E